



CERTIFICATE OF CONFORMITY TOUGHENED SAFETY GLASS

BS EN 12150: GLASS IN BUILDING THERMALLY TOUGHENED SODA LIME SILICATE SAFETY GLASS

THIS CERTIFICATE OF CONFORMITY CONFIRMS THAT THE PRODUCTS SUPPLIED BY THE COMPANY BELOW HAVE CONFORMED WITH CPR 305/2011 AND EN 12150-2 ANNEX ZA

UKCA MARK DECLARATION YEAR: 2025



**UNIT 2 BRIDGEWATER BUSINESS PARK, WEST BRIDGEWATER STREET,
LEIGH, LANCS. WN7 4HB**

TEST LABORATORY	TEST STANDARD	GLASS SPECIFICATION	TEST REPORT NUMBER	CLASSIFICATION
TUV Rheinalnd Nederland B.V.	12150: FRAGMENTATION	CLEAR	89218161-01	PASS
TUV Rheinalnd Nederland B.V.		OBSCURE	89218161-01	PASS
TUV Rheinalnd Nederland B.V.		SOFT COAT	89218161-02	PASS
TUV Rheinalnd Nederland B.V.		ACID ETCHED	89218161-04	PASS
TUV Rheinalnd Nederland B.V.		CERAMIC / ENAMELLED	89918161-03	PASS
TUV Rheinalnd Nederland B.V.	12600: PENDULUM IMPACT	CLEAR	89220074-120	1 (C) 1
TUV Rheinalnd Nederland B.V.		OBSCURE	89220074-120	1 (C) 3
TUV Rheinalnd Nederland B.V.		SOFT COAT	89220074-120	1 (C) 2
TUV Rheinalnd Nederland B.V.		ACID ETCHED	89220074-120	1 (C) 1
TUV Rheinalnd Nederland B.V.		CERAMIC / ENAMELLED	89220074-120	1 (C) 1
TUV Rheinalnd Nederland B.V.	EN 1288: FOUR POINT BEND TEST	CLEAR	89218161-01	PASS
TUV Rheinalnd Nederland B.V.		OBSCURE	89218161-01	PASS
TUV Rheinalnd Nederland B.V.		SOFT COAT	89218161-02	PASS
TUV Rheinalnd Nederland B.V.		ACID ETCHED	89218161-04	PASS
TUV Rheinalnd Nederland B.V.		CERAMIC / ENAMELLED	89218161-03	PASS

(a) SUBMITTING GLASS FOR INITIAL TYPE TESTING TO EN 12150, EN12600 AND SUCCESSFULLY MEETING ALL REQUIREMENTS.

(b) INSTIGATING AND IMPLEMENTING A SYSTEM OF FACTORY PRODUCTION CONTROL COMPLYING WITH BS EN 12150-2:2004

(c) PRODUCING A TECHNICAL FILE CONTAINING THE TEST REPORT AND PERFORMANCE INDICATION PAPERS FOR ALL COMPONENTS

Signed: *Wayne Fitzmartin*

Date: 01/12/2025

Position: Director